

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC POOL AND BATHING PLACE
INSPECTION REPORT



1 of 3

Facility Information

RESULT: Unsatisfactory

Permit Number: 58-60-00041
Name of Facility: North Port Aquatic Center Pool
Address: 5925 Greenwood Avenue
City, Zip: North Port 34287

Correct By: by 8:00 AM
Re-Inspection Date: 7/12/2019

Type: Public Pool > 25000 Gallons
Owner: Charlotte County Family YMCA
Person In Charge: Brittany Stokes Phone: (941) 429-2269
PIC Email:
Pool Operator: Lucy Linet - YMCA Phone: (941) 429-2269

Inspection Information

Purpose: Reinspection
Inspection Date: 6/28/2019

Begin Time: 03:50 PM
End Time: 04:30 PM

Additional Information

| | | |
|-------------------------------|-------------------|--------|
| 22. Free Chlor./Bromine | VOLUME | 159500 |
| 23. pH | POOL LOAD | 89 |
| 24. Chlor. Stabilizer | FLOW RATE | 443 |
| 33. Flowmeter | NIGHT SWIM | No |
| 34. Thermometer | FILTER TYPE | DEV |

Items checked are not in compliance with Chapter 386 or 514, Florida Statutes, or Chapter 64E-9 or 64E-10, Florida Administrative Code. These violations must be corrected by the date indicated to avoid closure, administrative fines, or other legal actions. Florida Building Code (FBC) violations are reported to the local building official, and depending upon risk severity, the Department of Health may close the pool or rescind the operating permit.

Violation Markings

| | | |
|--------------------------------|-----------------------------------|-----------------------------|
| POOL AREA | 17. Rules Posted | 32. Vacuum Cleaner-FBC |
| 1. Water Clarity/Algae Control | 18. Certification | 33. Flowmeter |
| 2. Deck/Walkways | SANITARY FACILITIES | 34. Thermometer |
| X 3. Tile/Pool Finish | 19. Supplies 64E-10, FAC | X 35. Pressure/Vacuum Gauge |
| 4. Depth Markers-FBC | 20. Clean 64E-10, FAC | 36. Equip. Room |
| 5. Handrail/Ladder-FBC | WATER QUALITY | 37. Cross Connection |
| 6. Step Markings-FBC | 21. Approved Test Kit | 38. Gas Chlorine Eq.-FBC |
| 7. Suction Outlets-514.0315(1) | 22. Free Chlor./Brom. | 39. Waste Water - FBC |
| 8. Gutter Grates/Skimmer-FBC | 23. pH | 40. D.E. Separator-FBC |
| 9. Lighting | 24. Chlor. Stabilizer | X 41. Other Equipment |
| 10. No Dive Markings-FBC | 25. Spa Requirements-ORP | 42. Equip. Change-FBC |
| 11. Diving Board-FBC | EQUIPMENT ROOM | 43. Approved Chemicals |
| 12. Pool Cover | 26. Wading Pool-Quick Dump | 44. Maintenance Log |
| 13. Pool Side Shower-FBC | 27. Water Level/Control | 45. Inspection Posted |
| POOL SAFETY | 28. Disinfection Feeder/Generator | 46. Safety-514.0315(2) |
| 14. Life Hook(s) w/Pole | 29. pH Feeder | 47. Fences/Gates- FBC |
| 15. Life Ring(s) w/Rope | 30. Chem. Container Label-FBC | 48. Other |
| 16. Safety Line | 31. Filter / Pump | 49. Other |

NOTE: It is unlawful to modify a public pool or its equipment without prior approval from the local building department and submitting an application to DOH.

Inspector Signature:

Jeff Clute

Client Signature:

emailed

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC POOL AND BATHING PLACE
INSPECTION REPORT



2 of 3

General Comments

Provide a timeframe for complete resurfacing of pool.

Pool will be immediately closed by DOH as not being in compliance whenever any of the following conditions occur:

*Disinfectant level is below the minimum (or above maximum) prescribed by 64E-9

*pH of pool water is below 7.2 or above 7.8

*The clarity of the pool water is such that the main drain grate is not readily visible from the pool deck

*Recirculation system or disinfection feeding equipment is missing or not functioning.

*Other conditions exist such as drowning hazard, sharp edges/broken tiles, fecal accident(s) or visible biological growth.

Low flowrate for pool recirculation is a violation of 64E-9 and FBC 454. Flowrate must be corrected within 90 days (9/22/19). Official Notice of the violation will be sent to the jurisdictional building official.

FBC 454.1.6.5.2 Volume.

The recirculation system shall be designed to provide a minimum of four turnovers of the pool

volume per day. Pools that are less than 1,000 square feet (93 m2) at health clubs shall be required to provide eight turnovers per day.

Email Address(es): bstokes@veniceymca.com;

spfundheller@cityofnorthport.com;

;

Twisner@cityofnorthport.com;

pshattuck@veniceymca.org;

lsaller@cityofnorthport.com

DOH Web Page For Pools: <http://www.floridahealth.gov/environmental-health/swimming-pools/index.html>

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC POOL AND BATHING PLACE
INSPECTION REPORT



3 of 3

Violations Comments

Violation #3. Tile/Pool Finish

Cracks in pool surface at the shallow end need to be patched. Please address by 7/12/19.

CODE REFERENCE: Tile/Pool Finish. 64E-9.004(3); 64E-9.017(1)(h). Pool finish and tile shall be maintained in a safe and sanitary condition.

Violation #35. Pressure/Vacuum Gauge

Provide a vacuum gauge before the recirculation pump.

CODE REFERENCE: Pressure/Vacuum Gauges. 64E-9.008(10)(d). All vacuum filter systems shall have a functional vacuum gauge before the pump. All pressure filter systems shall have a functional pressure gauge mounted before and after the filter.

Violation #41. Other Equipment

Maintain flowrate of 443gpm (within 20 percent). Repair equipment or plumbing as needed to attain the required flowrate. FBC type violation - must be corrected within 90 days. (9/22/19)

CODE REFERENCE: Other Equipment. 64E-9.008(10). Auxiliary equipment must not interfere with the attainment of the design flow, i.e. ionizers, UV, ozone generators, heaters, etc.

Inspection Conducted By: Jennifer Clemente (41964)

Inspector Contact Number: Work: 941-861-3310

Print Client Name: Manager

Date: 6/28/2019

Inspector Signature:

Client Signature: