

POTABLE WATER DEMAND				
Existing Demand				
Use	Units		GPD/unit	GPD
Country Club	250	Seats	40	10,000
Total Existing Demand				10,000
Proposed Demand				
Use	Units		GPD / Unit	GPD
Residential	500	units	250	125,000
Multi-Family	100	units	250	25,000
Assisted Living	300	Beds	125	37,500
Commercial	20,000	SF	0.1	2,000
Medical office Space	10	Practitioners	250	2500
	30	Employees	15	450
Mini-Storage	500	Units	1	500
Total Proposed Demand				192,950
Net Potable Water Demand Increase				
Proposed Demand - Existing Demand =				182,950